(Blue well)

Log No. 7347
Rec. Sept 3 1963
Well No.
Permit No.

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Do not fill in

Owner: Bureau of Land management Driller: J B Reynolds

Address: Elko Nev Address: Wells Nev Lic. No.

Location of well: NE ¼ SW ¼ Sec 36, T 29 N/S, R 60 E, in Elko County

or

Water will be used for: Stock Water Total depth of well: 277 ft

Size of drilled hole: 6" Weight of casing per linear foot: 18 lbs.

Thickness of casing: .219 Temp. of water: Cold

Diameter and length of casing: 6" X 277 ft.
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface: 11 ft

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well: July 17-63 Date of completion of well: July 27-63

Type of well rig: Churn drill.

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	46	46	sandy clay. small deposit water at 46'
46	175	129	Tough blue clay.
175	260	85	Fine sand & water
260	277	17	Fairly coarse water sand
			T-D 277 ft

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 260 to 277 ft.

Other aquifers: Two gals per minute at 46 to 48 feet.

First water at 46 feet.

Casing perforated
from 260 to 272 ft.
and from 46 to 80 ft.

Size of perforations
Mills Knife.

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
				6" Casing from 0 to 277 ft

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed J B Reynolds
Well Driller

By.....

License No. 28

Dated July 27, 1969

(Not to be filled in by Driller)

1969 SEP 3 AM 10 43

STATE ENGINEER
OFFICE