

7505
21150
1360
21150

**WELL LOG AND REPORT TO THE DIVISION OF WATER RESOURCES
STATE OF NEVADA**

[REDACTED]
Deepening of existing well
[REDACTED]

State _____ of _____ Nye State of Nevada
Permit No. 19660 of _____ Well No. _____ County _____

Owner Frank A. Sanderson

Address 3703 Mural Drive Claremont, Calif.

Driller R. P. Cope WellDrilling

Address 927 Poulsen Idaho Falls, Idaho

Well location NE 1/4 SW 1/4 Sec. 18, T. 6N N/S, R. 41 E. E/W

Size of drilled hole 12 inch

Total depth of well 400 ft.

Give depth to standing water from the ground 92 ft. Water temp. _____ °Fahr.

Test delivery was _____ g.p.m. or _____ c.f.s. Drawdown was _____ feet. Pump? _____ Bail? _____

Size of pump and motor used to make test _____

Length of time of test _____ hours _____ minutes.


If flowing well, give flow _____ c.f.s. or _____ g.p.m. and of shut off pressure _____

If flowing well, described control works _____
(TYPE AND SIZE OF VALVE, ETC.)

Water will be used for Irrigation _____ Weight of casing per lineal foot _____

Thickness of casing 250 wall Casing material Steel
(STEEL, CONCRETE, WOOD, ETC.)

Diameter, length and location of casing 200 ft. of 12 inch I.D. casing
(CASING 12" IN DIAMETER OR LESS, GIVE INSIDE DIAMETER;
CASING OVER 12" IN DIAMETER, GIVE OUTSIDE DIAMETER)



CASING RECORD

Diam. Casing	From Feet	To Feet	Length	Remarks—seals, grouting, etc.
12 in.	185	385	200 ft.	Corrosions 3/8 by 2 1/4 in. to the circle at intervals

