(1)

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 7698
Rec. Mar. 12, 1964
Well No.
Permit No. 20289
Do not fill in.

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner: Robert R. Craig Jr. Driller: Reno Pump & Supply

Address: 105 Bret Hart - Reno, Nev. Address: 7168 So. Virginia - Reno Lic. No. 285

Location of well: NE¼ SE¼ Sec. 1, T. 18 N/S, R. 20 E, in Washoe County

or

Water will be used for: ~~Domestic~~ IRR Total depth of well: 126'

Size of drilled hole: 8" Weight of casing per linear foot:

Thickness of casing: .188" Temp. of water: Cold

Diameter and length of casing: 8" x 126'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure: 10 gpm

If nonflowing well give depth of standing water from surface:

If flowing well describe control works: 1½" Gate Valves
(Type and size of valve, etc.)

Date of commencement of well: 3/1/63 Date of completion of well: 3/12/63

Type of well rig: Cable Tool

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	6	6	Top soil & gravel
6	10	4	Gray clay & gravel
10	20	10	Sandy clay & gravel W/B
20	30	10	Sandy clay W/B
30	85	55	Sandy clay & gravel W/B
85	95	10	Silt, sand, clay & small gravel W/B
95	110	15	Clay with sand & gravel W/B
110	121	11	Clay, sand & gravel stratified W/B
121	126	5	Sand W/B

Water-bearing Formation, Casing Perforations, etc.

Chief aquifer (water-bearing formation)
from 20 to 126 ft.

Other aquifers:
W/B

First water at 10 feet.

Casing perforated
from 93 to 125 ft.

Size of perforations
Torch Cut 1/8" x 4"

(OVER)

919

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
8"	0	126	126'	Drilled 6" hole along side of 8" so as to pump flowing well down so cement grout could be poured to the 20' level. Ernest Gregory of the State Health Dept. witnessed the pumping and approved the application.
6"	0	40'	40'	

GENERAL INFORMATION—Pumping Test, Quality of Water, etc.

Well flows over the top at about 10 GPM. Water sample was taken to Health Dept. and proved to be safe.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Reno Pump & Supply
Well Driller

By Harry W. Jones

License No. 285

Dated April 1, 1963

(Not to be filled in by Driller)

1964 MAR 12 AM 10 16