Log No. 8790
Rec. Sept 3 1966
Well No.
Permit No. 22081-26137
Do not fill in.

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner: Mr. Norman Sharp Driller: Gerald Sharp

Address: Nyala via Tonopah Nev. Address: Nyala via Tonopah Nev. Lic. No.

Location of well: NE ¼ SE ¼ Sec. 36, T. 5 N/S, R. 55 E, in Nye County

Permit No. 22081

Water will be used for: Irrigation and Domestic Total depth of well: 179 ft

Size of drilled hole: 22 inch Weight of casing per linear foot: 50 lb

Thickness of casing: 1/4" Temp. of water: 68° F

Diameter and length of casing: 16 in. 179'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure: Not

If nonflowing well give depth of standing water from surface: 50 ft

If flowing well describe control works: Not
(Type and size of valve, etc.)

Date of commencement of well: Nov 16-1965 Date of completion of well: Nov 30-1965

Type of well rig: Water-Well Reverse Rotary

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	16	16	Topsoil, clay & gravel
16	20	4	Clay
20	30	10	Clay, clay & gravel
30	40	10	Clay & gravel, sand etc.
40	50	10	Sand & gravel,
50	60	10	Gravel - (cobble stone)
60	70	10	Clay
70	79	9	Clay, (clay & gravel)
79	84	5	Gravel (some cobbles) (114 - 116)
84	86	2	Clay
86	89	3	Gravel (some cobbles)
89	93	4	Clay
93	100	7	Gravel (cobble stone)
100	113	13	Clay
113	114	1	Clay & gravel
114	116	2	Gravel - (fine)
116	121	5	Clay & gravel
121	144	23	Course gravel (cobble stone)
144	147	3	Clay & gravel
147	155	8	Sand & gravel (cobbles)
155	168	13	Course gravel
168	179	11	Course sand & gravel

(OVER)

Water-bearing Formation, Casing Perforations, etc.

Chief aquifer (water-bearing formation)

from 121' to 144' ft.

Other aquifers: 147' - 179'
50' - 60' 79' - 84'
86' - 89' (93 - 100)
(114 - 116)

First water at: 50 feet.

Casing perforated

from 60 to 179' ft.

Size of perforations: 3/16" X 3"

919

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
16"	0	179	179	

GENERAL INFORMATION—Pumping Test, or Boiling Test, Quality of Water, etc.

No Test Data available

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Gerald Sharp
Well Driller

By.....

License No.....

Dated Dec 5, 1965

(Not to be filled in by Driller)

1965 JAN 3 AM 11 23

OFFICE
STATE ENGINEER