

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material
			

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
16" 12*	plus 1 585	592 990	593' 405	Gravel packed from 50 to 592 - grouted to 50'

GENERAL INFORMATION—Pumping Test, Quality of Water, etc.

Pumping Test - 1250 gallons per min. from 250'

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Patricia H. Thompson
Well Driller

By

License No. 192

Dated 18 July, 19 66

(Not to be filled in by Driller)

RECEIVED

AUG 9 1966

DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA