

OFFICE USE ONLY
 Log No. 10085
 Permit No. _____
 Basin EAGLE VALLEY
CARD

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Vernon Millard ADDRESS 724 Highland Carson City

2. LOCATION S.W. 1/4 S.W. 1/4 Sec. 29 T. 15 N/R. 20 E. Ormsby County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy soil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Decomposed granite</u>		<u>3</u>	<u>32</u>	<u>29</u>
<u>clay</u>		<u>32</u>	<u>48</u>	<u>16</u>
<u>sand</u>	<input checked="" type="checkbox"/>	<u>48</u>	<u>50</u>	<u>2</u>
<u>clay</u>		<u>50</u>	<u>76</u>	<u>26</u>
<u>sand</u>	<input checked="" type="checkbox"/>	<u>76</u>	<u>92</u>	<u>16</u>
<u>clay</u>		<u>92</u>	<u>95</u>	<u>3</u>

8. WELL CONSTRUCTION
 Diameter hole 10" to 50 ft inches Total depth 95 feet
 Casing record 96 ft
 Weight per foot 9.7 lbs Thickness 10 ga
 Diameter " _____ From _____ To _____
6" inches 0 feet 95 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Plastic
 Depth of seal 50 ft feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory laminated
 Size perforation 3X7/32
 From 62 feet to 92 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ Feet below land surface 35
 Flow _____ G.P.M.
 Water temperature Cool F. Quality good

Date started 5-20, 1968
 Date completed 5-22, 1968

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 32 Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W. E. Blair
 Address Box 255 Carson City Nevada
 Nevada contractor's license number 5259
 Nevada driller's license number 301
 Signed W E Blair
 Date 6-6-68

Mr. Jay Flint,
March 1, 1961.
Page 2.

The reason for only pumping this well for 2½ hours was that the motor on the 1 HP jet pump on the well, and being used in the test was getting extremely hot; however we believe that the pumping level would remain at 48' for an indefinite period with the amount of water being pumped at the time and date the test was made. This is not an indication that the production rate will not vary later in the season, or at other demands are made on the underground water in the area.

For your personal information we would like to point out that cutting off any well casing on a domestic water system below, at least six inches above the natural ground level is in violation of the Nevada State Health Code. If you should be planning to re-drill this well, or to drill another domestic well we would suggest that you contact either the State Engineer's Office in Carson City, or the State Health Department in Reno, relative to the State Law governing the drilling of Domestic Water Wells.

We hope that this information will be helpful for your purpose. The securing of additional information as to the actual amount of casing installed in the well, the location of the perforations would have cost more than its value to you at this time.

Sincerely,

WATER INC.,


Bruce Bagwill,
President;

BB:BB

cc: State Engineer's Office.