DIVISION OF WATER RESOURCES

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10281
Permit No. 22619
Basin Stone Cabin CARD

SEE PERMIT APP 58909
PROBABLY: SECTION 03 ABCC 01

1. OWNER ELAINE. S. SACKELMAN ADDRESS

2. LOCATION SW ¼ NE ¼ Sec. 3 T. 3 N N/S R. 48 E NYE County
PERMIT NO. 22619, 24410 CANCELLED, 32612, DENIED

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☑ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coil and clay	85	6	7	7
Course gravel sand		7	125	118
Quality sand gravel		125	145	20
dry sand pack gravel		145	220	75
Water sand Large gravel		220	308	128

Date started March 3-1968 1968
Date completed 4-22 1968

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
—	—	—	—

BAILER TEST

G.P.M. — Draw down ✓ feet — hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 16 inches Total depth 306 feet
Casing record
Weight per foot 88 Thickness 1/4

Diameter	From	To
16 inches	0 feet	306 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Sand Gravel
Depth of seal 4 ft feet
Gravel packed: Yes ☐ No ☑
Gravel packed from — feet to — feet

Perforations:
Type perforation torch
Size perforation 1/2 by 10 inch 6 per ft
From 210 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 85 Feet below land surface 85
Flow — G.P.M. —
Water temperature 65 ° F. Quality —

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sam Gaffery
Address Elz nevada Elsinore notes
Nevada contractor's license number farmer One Rig
Nevada driller's license number 481
Signed Sam Gaffery
Date 4-26-1968

USE ADDITIONAL SHEETS IF NECESSARY

5471

KAWCHACK

Pump and Well Service — Sales and Service

O. Box ~~23~~ 536 — Phone ~~227-3671~~ 782-3044 — ~~Eureka~~ Gardnerville, Nevada 89316

WELL TESTING REPORT

OWNER Elaine S. Stickelman ADDRESS Minden

DESCRIPTION SW ¼ NE ¼ Sec. 3 T 3N R 18E MDM Ny. Co.

WELL NO. 1 DEPTH 306 CASING DIA. 16

PERFORATIONS FROM ____ TO ____ PUMP SETTING 220

COLUMN SIZE 8" BOWL SIZE 12" NO. STAGES 5

TYPE OF FLOW MEASUREMENT USED Square

SIZE ORIFICE ____ STATIC WATER LEVEL 110

PUMPING WATER LEVEL	MEASUREMENT	GALLONS PER MINUTE
134		800
164		1000
168		1500
174		2000
180		2400

REMARKS

DATE 9/30/68

SIGNED Steve Kawchack