

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29522

1. OWNER ATLANDIA DESIGN ADDRESS AT WELL LOCATION BELLASIO HOTEL WELL 'C'
 MAILING ADDRESS 3260 INDUSTRIAL ROAD
CAS VEGAS NEVADA
 2. LOCATION SW 1/4 NE 1/4 Sec. 20 T. 21 N. R. 61 E. CLARK County
 PERMIT NO. 63608T Issued by Water Resources Parcel No. 16220-501-002 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL WAS REPAIRED				
AND RECONDITIONED				
AND THE PUMP WAS				
REINSTALLED				
DCNR/DWR RECEIVED				
JUL 07 2006				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION
 Depth Drilled 1090 Feet Depth Cased 1070 Feet
 HOLE DIAMETER (BIT SIZE)
 From 36 Inches To 74.5 Feet
 From 26 Inches To 1090 Feet
 From Inches To Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		.312	12	610
16"		.312	870	950
16"		.312	1050	1070

Perforations:
 Type perforation JOHNSON Hi CAP
 Size perforation .060
 From 610 feet to 870 feet
 From 950 feet to 1050 feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 74.5
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 0 feet to 1090 feet

9. WATER LEVEL
 Static water level 9.3 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

Date started....., 20.....
 Date completed....., 20.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. Cleaned DRILLER'S CERTIFICATION
 This well was ~~drilled~~ under my supervision and the report is true to the best of my knowledge.
 Name LAYNE CHRISTENSEN Contractor
 Address 11001 ETIWANDA AVE Contractor
FONTANA CA 92337
 Nevada contractor's license number issued by the State Contractor's Board 0043608
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1660
 Signed M. Heer
 By driller performing actual drilling on site or contractor
 Date 7-5-06