WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100019
Permit No.
Basin 105

NOTICE OF INTENT NO. 56613

1. OWNER Marilyn Richardson
MAILING ADDRESS 1532 Johnson Ln.
Minden, NV 89423

ADDRESS AT WELL LOCATION 1532 Johnson Ln.

2. LOCATION SW 1/4 SE 1/4 Sec. 34 T 14N N/S R 20E E Douglas County
PERMIT NO. (Issued by Water Resources) | Parcel No. 1420-34-810-028 | Subdivision Name

3. WORK PERFORMED
- [ ] New Well
- [ ] Replace
- [ ] Recondition
- [x] Deepen
- [ ] Abandon
- [ ] Other

4. PROPOSED USE
- [x] Domestic
- [ ] Irrigation
- [ ] Test
- [ ] Municipal/Industrial
- [ ] Monitor
- [ ] Stock

6. WELL TYPE
- [ ] Cable
- [x] Rotary
- [ ] RVC
- [ ] Air
- [x] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand gravel		122	130	8
Brown clay		130	135	5
Coarse sand		135	150	15
Cobbles sand gravel	x	150	170	20
Sand gravel		170	195	25
Sand clay		195	205	10
Sand gravel	x	205	222	17

Date started 6/12/2006 , 19__
Date completed 6/13/2006 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		3

8. WELL CONSTRUCTION

Depth Drilled 222 Feet Depth Cased 222 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	122	Feet	222	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	102	222

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 152 feet to 172 feet
From 212 feet to 222 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [x] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL

Static water level 112 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 6/13/2006

USE ADDITIONAL SHEETS IF NECESSARY