



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59077

1. OWNER ANN Lewis ADDRESS AT WELL LOCATION 391 Pa Syhrs Springs Road GUNCH  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION SW SF SE NE 1/4 Sec. 30 T. 17 N/S R. 22 E. 140N County  
PERMIT NO. 19-254-11 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Rock		0	20	20
Cobble		20	50	30
Small Gravel		50	65	15
Assorted Gravel		65	110	45
Large Gravel		110	135	25
Chipped Rock and Gravel		135	190	55
Gravel		190	240	50

8. WELL CONSTRUCTION  
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 5/8 Inches To 2 1/2 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<del>4 1/2</del>				
<u>6 5/8</u>		<u>.188</u>	<u>1</u>	<u>20</u>
<u>6 5/8</u>		<u>SDR 21</u>	<u>20</u>	<u>240</u>

Perforations:  
Type perforation Grinder cut  
Size perforation 1/8 inch  
From 200 feet to 240 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 240 feet

9. WATER LEVEL  
Static water level 140 feet below land surface  
Artesian flow N/A G.P.M. 25 P.S.I.  
Water temperature Cold °F Quality Clear

Date started 4-26- 2006  
Date completed 4-28 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>2 hrs</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name \_\_\_\_\_ Contractor  
BLAIN DRILLING & PUMP CO. INC.  
Address \_\_\_\_\_ P.O. Box 1255  
\_\_\_\_\_  
Carson City, NV 89702

Nevada contractor's license number 46499  
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2134-11

Signed BSK  
By driller performing actual drilling on site or contractor  
Date 4-28-06