



STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 100034  
 Permit No. \_\_\_\_\_  
 Basin 207

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 56044

1. OWNER Wade Gardner ADDRESS AT WELL LOCATION N 1/2 Lot 7 Block 20  
 MAILING ADDRESS 1000 S. Pioche Hwy  
no. 32 Ely NV 89301  
 2. LOCATION SE 1/4 SW 1/4 Sec. 28 T. 12 N/S R. 62 E. white Pine County  
 PERMIT NO. NA Parcel No. 013-113-02 Subdivision Name Land town Plat  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	3	
Sandy clay		3	5.5	
Clay gravel		5.5	11	
Sandy clay		11	29	
gravel	water	29	30	
Sandy clay		30	35	
Clay <del>silt</del> silt		35	65	
Cemented gravel	water	65	77	
Clay silt		77	81	
gravel sand		81	90	
Clay silt		90	106	
gravel	water	106	108	
Clay silt		108	110	

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 90 Feet  
6 Inches 90 Feet 110 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.9</u>	<u>.188</u>	<u>1</u>	<u>110</u>

 Perforations:  
 Type perforation mill  
 Size perforation 1/2 x 2 1/2" x 6 row  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 70 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 90 feet

Date started May 15, 2006  
 Date completed June 1, 2006

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>30</u>	<u>1 hr</u>

9. WATER LEVEL  
 Static water level 27 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Maynard Well Drilling Contractor  
 Address Box 64 Lund NV 89317 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 047226  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556  
 Signed Owen Maynard  
 By driller performing actual drilling on site or contractor  
 Date June 16 - 06