



STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 100040
Permit No. _____
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56691

1. OWNE Norman Parsons
MAILING ADDRESS 500 Berney Rd Fallon, NV 89406
SW Fallon, NV 89406

ADDRESS AT WELL LOCATION Austin Hwy
Fallon, NV 89406

2. LOCATION ~~NW~~ 1/4 ~~SW~~ 1/4 Sec 36 T 19 R 29
PERMIT NO R-500 Parcel No. 007-932-31

Latitude 39.46853 Longitude -118.6833 WGS 84
Subdivision Name _____ County Churchill

3. WORK PERFORMED
New Well

4. PROPOSED USE
Domestic

5. WELL TYPE
Rotary-mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand	X	0	30	30

N 39.468629
W 118.682326 NAD27

8. WELL CONSTRUCTION

Depth Drilled 30 Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.3 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (inches)	Weight/Ft. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
6.625	12.92	0.188	20	30
6	3.85	0.258	0	20

Perforations:

Type perforation Saw Cut
Size perforation 0.125
From 27 feet to 30 feet

Surface Sea Yes No

Seal Type:

Depth of Seal 25

Concrete Grout

Placement Method: Pumped

Gravel Packed: Yes No

From 25 feet to 30 Feet

9. WATER LEVEL

Static Water Level 4 feet below land surfac

Artesian Flow G.P.M. P.S.I.

Water temperature ° F Qualit unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contracto

Address 403 McLean Road

Fallon, NV 89407

Contracto

Nevada contractor's license number 29064
issued by the State Contractor's

Nevada driller's license number issued by the 2307
Division of Water Resource, the on-site driller

Signe

By driller performing the actual drilling on site or contract

Date 6/5/2006

Date started 6/2/2006

Date completed 6/2/2006

7. WELL TEST DATA

TEST METHOD

Comments GPM Drawdown Time (Hours)

Comments	GPM	Drawdown	Time (Hours)