


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



office use only
Log No. 100048
Permit No.
Basin 103

NOTICE OF INTENT NO 57308

1. OWNER **Jon Hill** ADDRESS AT WELL LOCATION **13090 Seneca Rd**
MAILING ADDRESS **PO Box 825**
Yerington, NV
2. Location **SE 1/4 SE 1/4 Sec 12 T 17N R 22E** **Lyon** County
PERMIT NO. **PARCEL NO. 15-322-12** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE
 New Well Replace Recondition | Domestic Irrigation Test | Cable Rotary RVC
Deepen Abandon Other | Municipal/Industrial Monitor Stock | Air Other Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION				
Material	Water/Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)			Depth Cased
						From			To
Boulders		0	50	50	11 inches	0	feet	280	feet
Rock		50	125	75	inches		feet		feet
Rock & clay.		125	260	135	inches		feet		feet
Rock.		260	280	20					

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	280

Perforations:
Type Perforation **Factory**
Size perforation **3/32 x 3"**
From **200** feet to **220** feet
From **260** feet to **280** feet
From feet to feet
From feet to feet
From feet to feet
Surface Seal YES No Seal Type:
Depth of Seal **50** feet Neat Cement
Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From **50** feet to **280** feet

9. WATER LEVEL
Static water level **124** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cold** Degrees F Quality

Date started **5-8 -06**
Date completed **5-11 -06**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
	G.P.M.	Draw Down (Feet Below Static)	Time (hours)
	15	76	.5
	30	156	2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **786**

Signed Steve McKay
By driller performing actual drilling on site or contractor
Date **5-22 -06**

RECEIVED
2006 JUN -7 AM 11:04
STATE ENGINEERS OFFICE