WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100067
Permit No.
Basin 107

NOTICE OF INTENT NO. 56415

1. OWNER John W ~~[illegible]~~ Claveire
MAILING ADDRESS 4024 Pomona Way Livermore Calif 94550
ADDRESS AT WELL LOCATION 300 Eagle Place Smith Nev.

2. LOCATION ~~N 1/2~~ 1/4 ~~S 1/2~~ 1/4 Sec. 22 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. SE NE (Issued by Water Resources) 007-201-12 (Parcel No.) Sierra Desert View Estates (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil sandy		0	2	2
Clay + D-G		2	20	18
Brown clay		20	100	80
Brown clay fine gravel		100	140	40
Coarse gravel + sand	✓	140	180	40
brown clay		180	200	20
Coarse gravel + coarse sand	✓	200	240	40

Date started May 7, 2006
Date completed May 14, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60	20	3 hrs

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	240

Perforations:
Type perforation Factory saw slott
Size perforation 3/32 X 3
From 140 feet to 180 feet
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling (Contractor)
Address P.O. Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date May 27 — 06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627