


COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 100190
 Permit No. _____
 Basin 162
 NOTICE OF INTENT NO. 30011



PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Palm Harbor Homes ADDRESS AT WELL LOCATION 4051 W. Joann St.
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NE 1/4 Sec 23 T 20S N R 52 E Nye County
 PERMIT NO. 41-443-02 Golden Springs Ranch Ut:2, Lot:130

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown Clay		4	12	8
Brown Clay		12	80	68
Brown Clay/Caliche	X	80	117	37
Brown Clay	X	117	160	43

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches _____ Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.92	.28	0	160

Perforations:
 Type perforation Saw Cut
 Size perforation 1/4" width 8" long
 From 120 feet to 160 feet
 From _____ feet to _____ feet

**DCNR/DWR
 RECEIVED**

JUL 10 2006

LAS VEGAS OFFICE

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout-
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started July 3, 20 06
 Date completed July 3, 20 06

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>	<u>4</u>	<u>1/4</u>	

Name JIM PIKE WELL DRILLING, LLC. (CONTRACTOR)
 Address P.O. BOX 56 (CONTRACTOR)
PAHRUMP, NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date July 6, 2006