WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100202
Permit No.
Basin 230

NOTICE OF INTENT NO. 28772

1. OWNER Raul Gill
MAILING ADDRESS 8152 Winter Crest
Las Vegas, Nv. 89123

ADDRESS AT WELL LOCATION Bettles Rd.
Amargosa Valley, NV 89020

2. LOCATION NE ¼ SE ¼ Sec. 7 T. 17 N/S R. 49 E. NYE County
PERMIT NO. Issued by Water Resources | Parcel No. 19-401-14 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel w/sand		0	85	85
gravel	1st	85	100	15
limestone		100	105	5
white clay, w/limestone layers		105	175	70
gravel w/sand	2nd	175	185	10
tan clay		185	195	10
limestone		195	200	5
Bottom of Well			200	

DCNR/DWR
RECEIVED
JUL 13 2006
LAS VEGAS OFFICE

Date started 5/10, 2006
Date completed 5/12, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12 1/4	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	200
Surface Protective Casing:				
8	steel	.188		7

Perforations:
Type perforation Machined
Size perforation 1/8" x 3" every 12"
From 100 feet to 120 feet
From 140 feet to 160 feet
From 180 feet to 190 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 87 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. Contractor
Address HC 70 Box 543 Contractor
Amargosa Valley Nv 89020
Nevada contractor's license number issued by the State Contractor's Board 5326-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/11/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627