

OFFICE USE ONLY
 Log No. 100204
 Permit No. _____
 Basin. 230

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28773

1. OWNER Russell Hulse ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HC 61 Box 65 _____
Salmon Id. 83467 _____
 2. LOCATION SE 1/4 SE 1/4 Sec. 22 T. 16 N. R. 49 E. Nye _____ County
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. 19-541-09 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>gravel w/ sand</u>		<u>0</u>	<u>130</u>	<u>130</u>
<u>gravel</u>	<u>1st</u>	<u>130</u>	<u>150</u>	<u>20</u>
<u>limestone</u>		<u>150</u>	<u>155</u>	<u>5</u>
<u>sand w/ gravel</u>		<u>155</u>	<u>175</u>	<u>20</u>
<u>limestone</u>		<u>175</u>	<u>180</u>	<u>5</u>
<u>sand</u>	<u>2nd</u>	<u>180</u>	<u>190</u>	<u>10</u>
<u>sandy tan clay</u>		<u>190</u>	<u>210</u>	<u>20</u>
<u>limestone</u>		<u>210</u>	<u>220</u>	<u>10</u>
<u>Bottom of Well</u>			<u>220</u>	

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 220
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>220</u>
<u>8</u>	<u>steel</u>	<u>1.88</u>		<u>7</u>

Perforations:
 Type perforation Machined
 Size perforation 1/8" x 3" every 12"
 From 140 feet to 180 feet
 From 200 feet to 210 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 30' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 30 feet to 220 feet

DCNR/DWR
 RECEIVED
 JUL 13 2006
 LAS VEGAS OFFICE

9. WATER LEVEL
 Static water level 131 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 3/30 2006
 Date completed 4/11 2006

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Cook Drilling Co.
 Address HC 70 Box 543
Amargosa Valley NV. 89020
 Nevada contractor's license number issued by the State Contractor's Board 5376-A
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 2160
 Signed Russell Hulse
 By driller performing actual drilling on site or contractor
 Date 4/5/06