

OFFICE USE ONLY
 Log No. 100205
 Permit No. _____
 Basin 198

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25708

1. OWNER Shawn Dreitzer ADDRESS AT WELL LOCATION 1/2 mile so. on San Burgess Rd Lot #9 Dry Valley NV 89043
 MAILING ADDRESS 6104 Evergreen Ave L.V. NV 89107
 2. LOCATION S/W 1/4 N/W 1/4 Sec. 6 T. 1 N. R. 69 E. Lincoln County
 PERMIT NO. 012-060-26 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand-Boulders		0	75	75
Sand-gravel-Boulders	X	75	125	50
Fractured Rock	X	125	165	40
Hard Rock		165	170	5

8. WELL CONSTRUCTION
 Depth Drilled 170 Feet Depth Cased 170 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 170 Feet
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>MVC</u>	<u>Sch 40</u>	<u>0</u>	<u>170</u>

 Perforations:
 Type perforation 39W cut
 Size perforation 1 5/8" x 3"
 From 70' feet to 90' feet
 From 110' feet to 170' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 170 feet

DCNR/DWR
 RECEIVED

JUL 20 2006

LAS VEGAS OFFICE

Date started 6-28-06, 20
 Date completed 6-30-06, 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>2</u>

9. WATER LEVEL
 Static water level 81' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling & Pumps Contractor
 Address HC. 01 Box 54 Nika NV 89017 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0028966
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1191
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-3-06