



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT N^o 20074

1. OWNER Deer Springs Crossing LLC ADDRESS AT WELL LOCATION 6808 N 5th St
 MAILING ADDRESS _____
 2. LOCATION N.W. 1/4 SW 1/4 Sec. 23 T. 19 S. N/S R. 6.1 E. Clark County _____
 PERMIT NO. 124-23-341-910
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Depth of well 300 ft				
Dia. of well 8 5/8				
Pump and perforate from bottom up to 50 ft 4 times around				
Static water 70 ft				
Cement from bottom up to surface with neat 27 sac mix				
<p>Orig Log #27085</p> <p>DCNR/DWR RECEIVED</p> <p>JUL 24 2006</p> <p>LAS VEGAS OFFICE</p>				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From		To	
_____ Inches	_____ Feet	_____ Feet	_____ Inches
_____ Inches	_____ Feet	_____ Feet	_____ Inches
_____ Inches	_____ Feet	_____ Feet	_____ Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 7-5-06, 20 _____
 Date completed 7-6-06, 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Veron H. Dimech Contractor
 Address 5360 N. Bonita Vista Contractor
Las Vegas 89149

Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed VH Dimech
 By driller performing actual drilling on site or contractor
 Date 07-23-06