

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 100520
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30321

1. OWNER WYNN LAS VEGAS LLC ADDRESS AT WELL LOCATION 3141 S. LAS VEGAS BLVD.
 MAILING ADDRESS 3131 LAS VEGAS BLVD. S LAS VEGAS, NV
LAS VEGAS, NV 89109

2. LOCATION SE 1/4 SW 1/4 Sec 09 T 21 S R 61 E CLARK County
 PERMIT NO. 162-09-410-001

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
5-Monitor wells				
Asphalt & type II		0	2	2'
Silt		2	6	4
Brown alluvium & rock		6	13	7
Tan alluvium & rock		13	16	3
White alluvium & rock		16	19	3
Caliche		19	25	6
Caliche	xx	25	35	10
Wells are temporary well to be plugged within 9 months.				

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 35 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	pvc	sch40	0	35

Perforations:
 Type perforation Saw cut
 Size perforation 1/8x6" 4 around each foot
 From 30 feet to 35 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 35 feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow no G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 8/12, 20 06
 Date completed 8/12, 20 06

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

Name ALLEN DRILLING INC (CONTRACTOR)
 Address 4015 West Tompkins Ave. (CONTRACTOR)
Las Vegas, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8/15/06