

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56908

1. OWNER Richard Sears ADDRESS AT WELL LOCATION 6 miles East of Sctn 93 and Hwy 50 Spring Valley  
 MAILING ADDRESS HC 10 1963 South 17 East Ely NV 89301  
 2. LOCATION S/W 1/4 S/E 1/4 Sec 28 T 14 R 67 E White Pine County  
 PERMIT NO. 012-160-07 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand - Boulders	V	0	68	68
Reg gravel	V	68	78	10
Clay - Sand - Boulders	X	78	122	44
Fractured Rock	X	122	210	88
Hard Rock		210	215	5

8. WELL CONSTRUCTION  
 Depth Drilled 215 Feet Depth Cased 215 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 215 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>215</u>

Perforations:  
 Type perforation Spry cut  
 Size perforation 5/8" x 3 1/4"  
 From 60' feet to 80' feet  
 From 100' feet to 120' feet  
 From 140' feet to 160' feet  
 From 200' feet to 215' feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50' feet to 215' feet

9. WATER LEVEL  
 Static water level 58' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 62 °F Quality good

Date started 6-12-06, 20  
 Date completed 6-16-06, 20

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>90</u>		<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Davis Drilling + Pumps Contractor  
 Address HC 61 Box 54 Contractor  
Hiko NV 89017  
 Nevada contractor's license number issued by the State Contractor's Board 0028966  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1191  
 Signed Mike Davis  
 By driller performing actual drilling on site or contractor  
 Date 6-16-06