WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100567
Permit No.
Basin 066

NOTICE OF INTENT NO. 57020

1. OWNER Newmont mining Corp
MAILING ADDRESS Environmental Dept
P.O Box 69 Golconda NV, 89414

ADDRESS AT WELL LOCATION Twin Creeks mine Environmental Dept
30 miles north of Golconda, NV

2. LOCATION SW ¼ SE ¼ Sec. 29 T. 39 N/S R. 43 E. Humboldt County
PERMIT NO. SE NE
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. MW 29-7 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drill to 145' Alluvium all way.				
Do water test and get 7 gpm				
at 140' Drill 5 more feet and				
Build well-				
Set 30' slot Screen PVC				
and 115' of Blank PVC				
leave 3' sticking above ground				
Place #8 Sand in hole from				
145' to 108'				
place 3/8 hole plug in hole from				
108 to 50'				
Pour in 50' Cement Slurry.				
Develope hole. to clean water				
Set monument				
Pour Cement Pad for Rectistal				
4'X5'X6"				

Date started 6/5, 20 06
Date complated 6/7, 20 06

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
7	—	—

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 142 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	145

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½		SC 80	+3	-142

Perforations:
Type perforation Slot
Size perforation .020
From 142 feet to 112 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 145 feet to 110 feet

9. WATER LEVEL
Static water level 86' feet below land surface
Artesian flow no G.P.M. — P.S.I.
Water temperature — °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co Contractor
Address P.O. Box 2748 Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2089
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/7/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627