WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100572
Permit No.
Basin 066

NOTICE OF INTENT NO. 57021

1. OWNER Newmont mining Corp
MAILING ADDRESS Environmental Dept. P.O. Box 69 Golconda, NV 89414
ADDRESS AT WELL LOCATION Twin Creeks mine environmental Dept 30 miles north of Golconda, NV

2. LOCATION SW ¼ SE ¼ Sec. 29 T. 39 N/S R. 43 E. Humboldt County
PERMIT NO. SW SE NW SE MO-1408
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. MW29-8 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium to 115' TD				
H2O between 80 + 100'				
6-7 gpm at TD.				
Place 30' Screen on Bottom (110' to 80')				
and Blank from 80 to +3'				
Place #8 Sand in hole from				
115' to 75'				
Place 3/8 Hole Plug from 75'				
to 50'				
Pour Cement in top 50'				
weld monument on				
Develope well till Clean				
Pour Cement Radistal				
4X 6X 6"				

Date started 6-8, 2006
Date completed 6/13, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6	—	—

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 112 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	115

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½	SC 80	1/4	+3	-110

Perforations:
Type perforation Slot
Size perforation .020
From 110 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 115 feet to 75' feet

9. WATER LEVEL
Static water level 94 feet below land surface
Artesian flow NO G.P.M. — P.S.I.
Water temperature — °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Contractor
Address P.O. Box 2748 Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2089
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/13/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627