WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100574
Permit No.
Basin 207

NOTICE OF INTENT NO. 43207

1. OWNER Kent Montgomery
MAILING ADDRESS Po Box 93 Lund NV 89317
ADDRESS AT WELL LOCATION 510 N 100W Lund NV Lot 2 Block 22 Lund 10 acre plat

2. LOCATION NW ¼ SE ¼ Sec. 28 T. 12 N/S R. 62 E. White pine County
PERMIT NO. N/A (Issued by Water Resources) 13-112-07 (Parcel No.) Lund 10 acre plat (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	4	
gravel		4	5	
Sandy Clay		5	13	
gravel, clay		13	17	
Sandy clay		7	35	
gravel	water	35	36	
Sandy clay		36	55	
gravel	water	55	60	
Sandy clay		60	64	
gravel	water	64	65	
Sandy Clay		65	79	
gravel	water	79	84	
Sandy Clay		84	87	
gravel	water	87	88	
Sandy clay		88	94	
Sand gravel	water	94	96	
Sandy clay		96	111	
gravel	water	111	112	
Sandy clay		112	119	
gravel	water	119	120	
Sandy clay		120	130	

RECEIVED 05 AUG 30 AM 10:42 STATE ENGINEERS OFFICE

Date started June 10, 2005
Date completed July 25, 2005

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	20	1 hr

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 Inches	50 Feet	130 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.9	188	-1	9.5
4	PVC	Sch 40	9.5	130

Perforations:
Type perforation Factory cut
Size perforation .092
From 70 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Maynard Well Drilling (Contractor)
Address Po Box 64 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 042 226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Owen Maynard (By driller performing actual drilling on site or contractor)
Date Aug 1-2005

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627