

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55202

1. OWNER BARRICK Ruby Hill mine ADDRESS AT WELL LOCATION Eureka City  
MAILING ADDRESS P.O. Box 676 Eureka BAU fields  
89316  
2. LOCATION SE 1/4 NW 1/4 Sec 24 T. 19 N/S R. 53 E. Eureka County  
PERMIT NO. waiver MD-12963 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
soil		0	65	65'
muddy gravel		15	60	
Andi site		60	265	205'
<del>B.</del>				
BACK fill - Abandon bottom 200' with abandonite slurry by trimmic				

RECEIVED  
05 JUL -5 AM 11:51  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
Depth Drilled 265 Feet Depth Cased 60' Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
10" Inches 0 Feet 20' Feet  
6" Inches 20 Feet 265 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
2" 1/8 71 60  
Perforations:  
Type perforation vertical  
Size perforation 1/4  
From 40 feet to 60 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 39'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 60' feet to 39' feet

9. WATER LEVEL  
Static water level 8' feet below land surface  
Artesian flow  G.P.M. 15 P.S.I.  
Water temperature cold °F Quality good

Date started 06/21, 2005  
Date completed 06/22, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		<u>5 hrs</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Eklund Drilling Co Contractor  
Address 605 Union Pacific Way Contractor  
EIKU NV 89203  
Nevada contractor's license number issued by the State Contractor's Board 030823  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2262  
Signed Frank Stephens  
By driller performing actual drilling on site or contractor  
Date 06/22/05