

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29861

1. OWNER Dept of Public Works ADDRESS AT WELL LOCATION 3195 W Corner  
 MAILING ADDRESS 500 S Grand Central Pkwy Rd, Las Vegas, NV 89141  
Las Vegas NV, 89155 3195 W. Silverado Ranch Blvd  
 2. LOCATION NE 1/4 NW 1/4 Sec 29 T 22 N R 61 E Clark County Sly  
 PERMIT NO. 177-29-103-001 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned 8" well to 290' Depth. Pulled system. Existing Perforations from 210' to the bottom.				
Perforated 8" steel casing from 210' to 130' and Pumped in 5 yards of neat cement through a tremmie line to 20'				
Poured surface Plug from 20' to the surface with Concrete Grout to completely Plug well.				
Plugging of Log 29082				
DCNR/DWR RECEIVED				
AUG 24 2006				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION  
 Depth Drilled 290 Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>8"</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_

From	To
_____ feet to _____ feet	_____ feet to _____ feet
_____ feet to _____ feet	_____ feet to _____ feet
_____ feet to _____ feet	_____ feet to _____ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 180 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name T.D.C. Water Well Drilling Contractor  
 Address 2870 W Pebble Rd Contractor  
Las Vegas, NV 89123

Nevada contractor's license number 59948  
 issued by the State Contractor's Board

Nevada driller's license number issued by the 2316  
 Division of Water Resources, the on-site driller

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date 8/24/06

Date started 8/11/06  
 Date completed 8/21/06

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)