


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 100645
 Permit No. 73558
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29921

1. OWNER PIV LLC ADDRESS AT WELL LOCATION 1371 N LINDA
 MAILING ADDRESS 1371 N LINDA
PAHRUMP, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 4 T 20S N/S R 53E E NYE County
 PERMIT NO. 73558 35-041-10 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	78	78
CALICHE	WB	78	92	14
CLAY		92	123	31
CALICHE	WB	123	136	13
CLAY		136	154	18
CALICHE	WB	154	172	18
CLAY		172	210	38
CALICHE	WB	210	223	13
CLAY		223	256	33
GRAVEL	WB	256	269	13
CLAY		269	284	15
GRAVEL	WB	284	296	12
CLAY		296	324	28
CALICHE	WB	324	344	20
CLAY		344	364	20
CALICHE	WB	364	378	14
CLAY		378	395	17
CALICHE	WB	395	400	5

DCNR/DWR RECEIVED

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 400
10.25 Inches Feet
 Inches Feet
 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8" STEEL	16.94	.188	0	400

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From	To
140	200
270	240
280	300
320	360
380	400

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 400 feet

Date started 8/17/2006, 19
 Date completed 8/21/2006, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 6.2 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address 1220 E. MANSE RD Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 8/21/2006