WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100657
Permit No. 61613
Basin 203

NOTICE OF INTENT NO. 28431

1. OWNER John Wadsworth
MAILING ADDRESS PO Box 256 Panaca, Nv. 89042
ADDRESS AT WELL LOCATION 2100 S. 200 W. Panaca, Nv. 89042

2. LOCATION NW ¼ SW ¼ Sec. 17 T. 2 N OR 68 E. Lincoln County
PERMIT NO. 61613 (Issued by Water Resources) | 012-200-08 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, clay			0	7
Clay - grey		7	42	35
Sand, gravel	X	42	78	36
Clay - grey		78	104	26
Sand, gravel, cobble	X	104	168	64
Clay - red, orange		168	180	12

DCNR/DWR RECEIVED
AUG 2 0 2006
LAS VEGAS OFFICE

Date started June 12, 2006
Date completed June 16, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
June 15	800		6 hrs

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	62.4	.375	0	180

Perforations:
Type perforation Factory milled
Size perforation 3/16 x 2 1/2
From 60 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 52'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 52 feet to 180 feet

9. WATER LEVEL
Static water level 16.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Webber Drilling (Contractor)
Address 2475 W. 3935 S. (Contractor) WVC, Ut. 84119
Nevada contractor's license number issued by the State Contractor's Board 0025887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
Signed Bryan Anzalone (By driller performing actual drilling on site or contractor)
Date July 30, 2006

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627