



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28429

1. OWNER Henry Bulloch ADDRESS AT WELL LOCATION 1 mile SW of Echo Dam NR 86 Dry Valley  
 MAILING ADDRESS PO Box 3174 Cedar City, UT 84720

2. LOCATION SE 1/4 NE 1/4 Sec. 6 T. 1 N. OR 69 E Lincoln County  
 PERMIT NO. 20829 | 012-060-14 | Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material           | Water Strata | From | To  | Thick-ness |
|--------------------|--------------|------|-----|------------|
| Sand, clay         |              | 0    | 4   | 4          |
| Clay               |              | 4    | 13  | 9          |
| silt, sand, clay   |              | 13   | 44  | 31         |
| Clay               |              | 44   | 48  | 4          |
| silt, sand, gravel | X            | 48   | 112 | 64         |
| clay               |              | 112  | 116 | 4          |
| silt, sand, gravel | X            | 116  | 200 | 84         |

DCNR/DWR  
 RECEIVED  
 AUG 29 2006  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 16                 | 62.4                | .375                    | 0           | 200       |

Perforations:  
 Type perforation Factory milled  
 Size perforation 3/16 x 2 1/2

From 80 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 54'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 54 feet to 200 feet

9. WATER LEVEL  
 Static water level 28.3 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Webber Drilling Contractor  
 Address 2475 W. 3935 S. WVC, UT 84119 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0025887  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238

Signed Bryan Anzalone  
 By driller performing actual drilling on site or contractor  
 Date Aug. 24, 2006

Date started June 3, 2006  
 Date completed June 12, 2006

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

|               | G.P.M.      | Draw Down (Feet Below Static) | Time (Hours) |
|---------------|-------------|-------------------------------|--------------|
| <u>Aug 20</u> | <u>1400</u> | <u>31</u>                     | <u>24</u>    |