WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100662
Permit No. 58506
Basin 212

NOTICE OF INTENT NO. 30357

1. OWNER IGWT LLC
MAILING ADDRESS 550 S. Hills ST
Los Angeles, Ca. 90013
ADDRESS AT WELL LOCATION Frontier Village
355 E. Larson, Henderson NV. 89044

2. LOCATION NE ¼ NE ¼ Sec. 16 T 23 South N/S R 61 E County
PERMIT NO. 58506 (Issued by Water Resources) 191-16-501-003 (Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☑ Recondition
☐ Deepen ☐ Abandon ☐ Other 9m

4. PROPOSED USE Commercial
☐ Domestic ☐ Irrigation ☐ Test
~~☑ Municipal/Industrial~~ ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 571 ft				
Pvc 5½ inch casing				
free standing liner.				
Wire brush original				
Casing fast bail.				
Reinstall 555 ft PVC				
Casing free standing				
liner inside 8 5/8				
inch original casing.				

DCNR/DWR
RECEIVED
AUG 30 2006
LAS VEGAS OFFICE

Date started 7/21/06, 20
Date completed 7/25/06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22		2HRS

8. WELL CONSTRUCTION
Depth Drilled 571 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5½"	PVC		+1	555

Perforations:
Type perforation Saw Cut
Size perforation 1/16 Four Row
From feet to feet
From 515 feet to 555 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 336 feet below land surface
Artesian flow Test Pump 22 G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling (Contractor)
Address 4930 Utah Ave (Contractor)
Las Vegas, NV 89104
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2120T1
Signed (By driller performing actual drilling on site or contractor)
Date 8-30-06

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627