

37° 27.239 N 7 / 118° 00.520 W 5

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 100665  
Permit No. \_\_\_\_\_  
Basin. 117

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

### WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25460  
Lot 34 Burd. In

1. OWNER Sara Green ADDRESS AT WELL LOCATION Dyer  
MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 SE 1/4 Sec. 5 T 45 N 36 E County Esmeralda  
PERMIT NO. 007-65-114 Parcel No. Waigod Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/W/Clay Shingles		1	7	
Sand		7	83	
Coarsed Sand		83	143	
Sand		143	156	
Coarsed Cobble		156	163	
Sand		163	176	
Coarsed		176	185	
Sand Cobble		185	200	

8. WELL CONSTRUCTION  
Depth Drilled 200 Feet Depth Cased 201 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
109/8 Inches 1 Feet 50 Feet  
83/8 Inches 20 Feet 200 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>105/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>21</u>
<u>63/8</u>	<u>PVC</u>	<u>SH 40</u>	<u>21</u>	<u>200</u>

Perforations:  
Type perforation Main Hole  
Size perforation 3/16 x 4 x 4  
From 170 feet to 200 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50+  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 20 feet to 200 feet

DCNR/DWR  
RECEIVED

SEP 01 2006

LAS VEGAS OFFICE

Date started 7/31/06, 20 \_\_\_\_\_  
Date completed 7/31/06, 20 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>2h</u>

9. WATER LEVEL  
Static water level 82 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Dylan J Contractor  
Address Pa Ben SPP Contractor  
85 NW 89428  
Nevada contractor's license number issued by the State Contractor's Board 0031841  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2876

Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 8/1/06