

27° 37.196 N 118° 00317 W

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 100669  
Permit No.  
Basin. 117

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25459

1. OWNER Mike Goss ADDRESS AT WELL LOCATION Lot # 38  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION NW 1/4 SW 1/4 Sec 5 T 4 S N/S R. 36 E Comdale County \_\_\_\_\_  
PERMIT NO. 007-00-19 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		1	3	
Clay		3	16	
Gravel		16	43	
Clay		43	76	
Gravel		76	94	
Clay		94	127	
Gravel		127	153	
Clayland		153	180	
Gravel		180	195	
Clay		195	216	
Gravel		216	228	
Clay		228	237	
Gravel		237	240	

8. WELL CONSTRUCTION  
Depth Drilled 240 Feet Depth Cased 240 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 3/8 Inches To 240 Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
6 5/8 13 188 1 21  
6 5/8 PVC SN 40 21 240  
Perforations:  
Type perforation Mechan Dr P  
Size perforation 1 7/8 x 5 Holes  
From 227 feet to 239 feet  
From 200 feet to 220 feet  
Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement/Grout  Concrete Grout  
Depth of Seal 50  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 50 feet to 240 feet  
9. WATER LEVEL  
Static water level \_\_\_\_\_ feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 88 °F Quality Good

Date started 8/24/06, 20\_\_\_\_\_  
Date completed 8/24/06, 20\_\_\_\_\_  
7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>		<u>1 1/2</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name John Dullin Jr Contractor  
Address PO Box 588 Contractor  
28 NW 82428  
Nevada contractor's license number issued by the State Contractor's Board 0031841  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 8/25/06

DCNR/DWR  
RECEIVED

SEP 11 2006

LAS VEGAS OFFICE