


Log No. 100673

Permit No. \_\_\_\_\_

Basin. 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28311

1. OWNER MIETZNER KENNETH N ADDRESS AT WELL LOCATION 1111 E WRIGHT PL.  
 MAILING ADDRESS 1381 E MITCHELL PL PAHRUMP NV  
PAHRUMP NV.  
 2. LOCATION NW 1/4 NW 1/4 Sec. 26 T. 19 N/S R. 53 E Nye County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. 033-031-31 Subdivision Name CALVADA MEADOWS

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY + GRAVEL		0	2	2
CLAY + SAND		2	125	123
SAND + GRAVEL		123	158	35
SAND + GRAVEL	X	158	161	3
CLAY + GRAVEL	X	161	166	5
SAND + GRAVEL	X	166	185	9
CLAY		185	200	15

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 195 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>SCH 40</u>	<u>0</u>	<u>195</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation 1/2" x 6"  
 From 135 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 123 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality GOOD

Date started 6-5- 2006  
 Date completed 8-26- 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>25</u>	<u>17</u>	<u>1/2 hour</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name LARRY'S WATER WELL SERVICE Contractor  
 Address PO BOX 3392 PAHRUMP NV Contractor  
89041  
 Nevada contractor's license number issued by the State Contractor's Board 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2301  
 Signed Dale W. Little  
 By driller performing actual drilling on site or contractor  
 Date 8-28-06

DCNR/DWR  
 RECEIVED

SEP 01 2006

LAS VEGAS OFFICE