

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 100716

Permit No. _____

Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37669

1. OWNER Clark County Parks & Community Services
MAILING ADDRESS 2601 East Sunset Road
Las Vegas, NV 89120

ADDRESS AT WELL LOCATION 201 Via Anticentido
Henderson, NV 89015

Subdivision Name: Powerline Weir Crossing 3.3 County: Clark

2. LOCATION SW 1/4 SE 1/4 Sec 21 T 21S N/S R 63 E
PERMIT/WAIVER No. DW-1214 160-21-810-027
Issued by Water Resources Parcel No.

Latitude See Attached UTM E NAD 27
Longitude See Attached N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE dentistry
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Backhoe/Hand

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
<u>See Attached</u>				
<u>for wells 10 thru 14</u>				
DCNR/DWR RECEIVED				
<u>AUG 23 2006</u>				
LAS VEGAS OFFICE				
Date started:	<u>27-Mar</u>		<u>20</u>	<u>06</u>
Date completed:	<u>27-Mar</u>		<u>20</u>	<u>06</u>

9. WELL CONSTRUCTION				
Depth Drilled	Feet	Depth Cased	Feet	
<u>52</u>		<u>52</u>		
HOLE DIAMETER (BIT SIZE)				
	From	To		
<u>24</u>	Inches <u>0</u>	Feet <u>52</u>	Feet	
	Inches	Feet	Feet	
	Inches	Feet	Feet	
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>5.7</u>	<u>.332</u>	<u>0</u>	<u>52</u>
Perforations:				
Type of perforation	<u>machine</u>			
Size of perforation	<u>0.032</u>			
From <u>12</u>	feet to	<u>52</u>	feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	
Annular Seal: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
<input type="checkbox"/> Neat Cement	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> <u>Temporary</u> Bentonite Grout <u>10</u> to <u>11</u>			<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Gravel Pack: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<u>0'</u>	to <u>52</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	<u>3/8 Pea Gravel</u>			
Bentonite Chips: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<u>10</u>	to <u>11</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	<u>3/8 s</u>			

7. Water Level
Static water level: 18 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Viking Drillers, Inc
Contractor
Address 801 Northport Dr.
Contractor
W. Sacramento, CA 95691
Nevada contractor's license number
issued by the State Contractor's Board 0034680
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller M-2091
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 5/9/2006

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>N/A</u>		