



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29859

1. OWNER Ramon Sanchez ADDRESS AT WELL LOCATION Corner of Linden Ave and Shrieber St and Los Feliz
 MAILING ADDRESS 5160 S Rogers St Las Vegas, NV 89118
 2. LOCATION NW 1/4 NE 1/4 Sec. 35 T. 20 N R 62 E Clark County
 PERMIT NO. 56854 | 140-35-501-036 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned 8 inch well to 497' Depth.				
Existing perforations from 497' to 417'				
Perforated casing from 417' to 190'				
Pumped in 5 yards of neat cement through a tremmie line to 190'				
Poured concrete grout (4 yards) from 190' to the surface completely filling well.				
Plugging of log 72841				

8. WELL CONSTRUCTION
 Depth Drilled 497' Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8				

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 240' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name T-D.C Water Well Drilling Contractor

Date started 9/14/2006
 Date completed 9/16/2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Address 2870 W Pebble Rd Las Vegas NV, 89123 Contractor
 Nevada contractor's license number 59948 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 9/18/06