WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100811
Permit No. 58317
Basin 212

NOTICE OF INTENT NO. 30089

1. OWNER School Board of Trustees
MAILING ADDRESS
ADDRESS AT WELL LOCATION Dr. C. Roundy School Lindell Rd & Tara Ave

2. LOCATION SW ¼ NE ¼ Sec. 12 T. 21 N/S R. 60 E. Clark County
PERMIT NO. 58317 (Issued by Water Resources) 163-12-601 007 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon Well 8 5/8" .188 wall 370 ft				
280 ft 12 3/4" .250" 34 lbs ft.				
Cemented in 50 ft from original log.				
Perforated 8 5/8 casing from				
370 ft up to 150 ft				
Static Water 210 ft.				
Cemented to surface with				
27 sack Neat Cement with				
Cement Pump + Tremie Pipe				
5 yds Neat Cement				
Original Log attached				
To Explain these odd				
Circumstances.				
Plugging of Log 42287				

UNR/DWR RECEIVED SEP 21 2006 LAS VEGAS OFFICE

Date started 09-19-06, 20
Date complated 09-21-06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Air Operated
Size perforation Perforator 3/16 x 2"
From feet to feet
From 4 times around feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 210 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista St (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 09-21-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627