

SVE 8

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 100855  
Permit No. \_\_\_\_\_  
Basin. 222

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30470

1. OWNER M. A. Burns ADDRESS AT WELL LOCATION 450 W. Mesquite Blvd  
 MAILING ADDRESS 18001 Old Cutler Rd  
MIAMI FL 33157  
 2. LOCATION NW 1/4 SE 1/4 Sec 17 T 13 N/S R 7' E Clark County  
 PERMIT NO. 00117701014 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>fill</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>silty sand</u>		<u>2</u>	<u>13</u>	<u>11</u>
<u>silty clay</u>		<u>13</u>	<u>14.5</u>	<u>1.5</u>
<u>silty sand</u>		<u>14.5</u>	<u>23</u>	<u>8.5</u>
<u>silty clay</u>		<u>23.0</u>	<u>24.5</u>	<u>1.5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 24 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 2.5  
8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>Sch 40</u>	<u>0</u>	<u>6</u>

Perforations:  
 Type perforation machine slot  
 Size perforation .010  
 From 6.0 feet to 24.0 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 5  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 5 feet to 24 feet

9. WATER LEVEL  
 Static water level 16.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge. Cascade Drilling  
 Name Shannon Magnus Contractor  
 Address 555 S. Harbor Blvd Contractor  
LA Habra CA 90631  
 Nevada contractor's license number C-23-51207  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the M-19-08  
 Division of Water Resources, the on-site driller  
 Signed Shannon F. Magnus  
 By driller performing actual drilling on site or contractor  
 Date 8/28/06

Date started 8/23/06, 20\_\_\_\_  
 Date completed 8/23/06, 20\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			