WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100866
Permit No.
Basin 104

NOTICE OF INTENT NO. 58057

1. OWNER K&S Properties / A California Partnership
MAILING ADDRESS 3130 Air Way Ave.
Costa Mesa, CA 92626

ADDRESS AT WELL LOCATION 5650 South Carson St.
Carson City, NV. (Old Bodines Resturant location)

2. LOCATION SE 1/4 SE 1/4 Sec. 31 T 15N N/S R 20E E Carson County
PERMIT NO. 12279 (Issued by Water Resources) 09-303-08 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 105' of 1-1/4" drop pipe and pump from 8" well. Measured static water level at 31.2' and depth of well at 110'. Installed 8" Mills Knife and perforated 4 rows per foot from 84' back to surface. Installed 105' of 2" tremme pipe and tried to clean well with air but hit a hard bottom at 110'. We then had neat cement delivered and pumped in approximately 2 cubic yards from bottom of well to surface. Casing was cutoff 5' below ground level. GPS location is 39 degrees - 6.945 North and 119 degrees-46.423 west				
	WGS84			

Date started 7/17/2006, 19__
Date completed 8/23/2006, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2006 SEP 12 AM 10:51
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 110' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		.188	+1	110'

Perforations:
Type perforation Mills Knife
Size perforation
From 84' feet to surface feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 110'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 31.2' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed ____ (By driller performing actual drilling on-site or contractor)
Date 9/11/2006

USE ADDITIONAL SHEETS IF NECESSARY