WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100906
Permit No.
Basin 104

NOTICE OF INTENT NO. 58061

1. OWNER K&S Properties / A California Partnership
MAILING ADDRESS 3130 Air Way Avenue
Costa Mesa, CA 92626

ADDRESS AT WELL LOCATION 5650 South Carson St.
Carson City, NV. (old Bodines Resturant location)

2. LOCATION SE 1/4 SE 1/4 Sec. 31 T 15N N/S R 20E E Carson County
PERMIT NO. Issued by Water Resources | Parcel No. 09-303-08 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
6" well: Measured water level at 31.1' and depth of well at 105'. Installed 6" mills knife to 84' and perforated 4 rows per foot from 84' back to surface. Installed 105' of tremme pipe and using air compressor, attempted to blow debris from well. We only gained 1' to a depth of 106'. We then pumped in1.25 yards of neat cement from bottom of well to surface. GPS location - 39 degrees 6.950 north and 119 degrees, 46.422 west				
WGS84				

Date started 7/17/2006 , 19__
Date completed 8/23/2006 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2006 SEP 12 AM 10:51
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 106' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	106'	+1

Perforations:
Type perforation Mills Knife
Size perforation
From 84' feet to surface feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 106'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 31.1' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Tramper
By driller performing actual drilling on-site or contractor
Date 9/11/2006

USE ADDITIONAL SHEETS IF NECESSARY