WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100911
Permit No.
Basin 106

NOTICE OF INTENT NO. 58142

1. OWNER Jose + Patricia Posada
MAILING ADDRESS 3571 Ralph Dr. South Lake Tahoe Ca. 96150
ADDRESS AT WELL LOCATION Parcel No. 3 East Side Sn. Topaz

2. LOCATION NE ¼ NE ¼ Sec. 18 T. 9 N/S R. 23 E. Douglas County
PERMIT NO. 092318000003 (Issued by Water Resources) 092318000003 (Parcel No.) Topaz Hylands 3 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Pan		0	2	2
Clay Brown + Fine gravel		2	15	13
Coarse gravel		15	80	65
fine gravel		80	120	40
Coarse gravel		120	160	20
Brown clay		160	200	40
Brown + fine gravel		200	220	20
Hard brown clay		320	340	20
gravel	yes	340	400	60

UTM E 0287617
N 4280514
NAD 27

RECEIVED 2006 SEP 14 AM 11:06 STATE ENGINEER'S OFFICE

Date started Aug 15, 2006
Date completed Sept 10, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	350	3

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	400 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	400

Perforations:
Type perforation Factory saw slott
Size perforation 3 3/2 X 3
From 340 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 320 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling (Contractor)
Address P.O Box 92 Smith Nev. 89430 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 32166A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date Sept 11 – 06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627