

Log No. 100933

Permit No.

Basin. 048

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58023

1. OWNER B & B Investments ADDRESS AT WELL LOCATION: None established
 MAILING ADDRESS: 555 Pine St. Elko, NV 89801

2. LOCATION: S.W. 1/4 NE 1/4 Sec. 23 T. 32 N. R. 55 E. Elko County
 PERMIT NO. 02T-38-009 Lucky Nugget Ranches
Issued by Water Resources Parcel No. 009 Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE: Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE: Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sail		0	1	1
Clay & gravel		1	12	11
Gravel		12	27	15
Clay		27	47	20
Clay, sand, gravel	✓	47	56	9
Sandy clay	✓	56	72	16
Clay		72	142	70
Streaks of clay				
Sand & gravel	rvv	142	158	16
Clay		158	160	2

T.D. 160
 Bailed static down
 55' in graded
 pour grout seal

G.P.S. [REDACTED]

40° 38' 139 N
 115° 48' 899 W W6984

RECEIVED
 2006 SEP 20 AM 11
 STATE ENGINEERS

8. WELL CONSTRUCTION

Depth Drilled: 160 Feet Depth Cased: 161 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10.7</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>8.7</u> Inches	<u>50</u> Feet <u>160</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.98</u>	<u>.188</u>	<u>+1</u>	<u>160</u>

Perforations:
 Type perforation: torch cut
 Size perforation: 1/8 x 3 x 2/ft

From _____ feet to _____ feet
 From 140 feet to 80 feet
 From 60 feet to 80 feet
 From 140 feet to 158 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal: 5 x 50 ft
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 160 feet

Date started: 8-22-06, 19
 Date completed: 8-26-06, 19

9. WATER LEVEL

Static water level: 47 ft feet below land surface
 Artesian flow: 0 G.P.M. P.S.I.
 Water temperature: cold °F Quality: Good

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>5</u>	<u>1 hr.</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: Math Drilling Co. Contractor
 Address: 203 Pine St. Elko, NV 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board: 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 632

Signed: James V. Math
 By driller performing actual drilling on site or contractor
 Date: 9-15-06