COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100936
Permit No.
Basin 165

NOTICE OF INTENT NO. 58215

1. OWNER GREG DAVIES CONSTRUCTION
MAILING ADDRESS P.O. BOX 22
GARDNERVILLE, NV 89410
ADDRESS AT WELL LOCATION 1727 NORTH BENTON
GARDNERVILLE, NV 89410

2. LOCATION ~~NE~~ SW ¼ NE ¼ Sec 26 T 13 N R 20 E DOUGLAS County
PERMIT NO. (Issued by Water Resources) 1320-26-001-034 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
HARD PAN CLAY		3	9	6
COURSE DG GRAVELS		9	45	36
BROWN CLAY		45	110	65
SMALL OBSIDIAN GRAVELS		110	162	525
BROWN GUMMY CLAY		162	203	41
FRACTURED GRAVELS SMALL SILTY SAND LAYERS	XXX	203	250	47

GPS INFO :
38.96186° N
119.70106° W
NAD83

Date started 8/10, 20 06
Date completed 8/11, 20 06

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	65	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	10
6 5/8 sdr 21	4.06	.216	10	250

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 250 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89410
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 8/28/06

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429