STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 100992
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30423

1. OWNER Perini Const.
MAILING ADDRESS 6370 S. Polaris
Las Vegas, NV 89113

ADDRESS AT WELL LOCATION 3600 S. Las Vegas Blvd.
Las Vegas, NV 89119
Subdivision Name: City Center County: Clark

2. LOCATION SW ¼ NE ¼ Sec 20 T 21S N/S R 61 E
PERMIT/WAIVER No. DW-1226 (Issued by Water Resources) 162-20-603-012 (Parcel No.)
Latitude E 253.48700 UTM E ☐ NAD 27
Longitude N 353.08500 N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock
dewatering

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
See attached for Well #4				
There are 9 wells on this parcel #				
Individual well logs submitted by driller for each well on this parcel				

DCNR/DWR RECEIVED
OCT 06 2006
LAS VEGAS OFFICE

Date started: 11-Aug , 20
Date completed: 11-Aug , 20

9. WELL CONSTRUCTION
Depth Drilled 41 Feet Depth Cased 41 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	41	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	12.5	.5	0	41

Perforations:
Type of perforation Machine
Size of perforation 0.032
From 0 feet to 41 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
temporary
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No 0 to 41 ☐ Pumped ☒ Poured
Type: 3/8's
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: na feet below land surface
Artesian Flow: na G.P.M. na P.S.I.
Water Temperature: na °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
na			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Viking Drillers, Inc. (Contractor)
Address 801 Northport Dr. (Contractor)
West Sacramento, CA 95691
Nevada contractor's license number issued by the *State Contractor's Board* 0034680
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2091
Signed (By driller performing actual drilling on site or contractor)
Date 9/25/2006

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

209150992

THIS BORING LOG IS FOR VIKING'S INTERNAL PURPOSES ONLY. IT DOES NOT REPRESENT INFORMATION PROVIDED BY A SOILS ENGINEER

LOG FOR BORING NO. 4		JOB NAME: Cattrac			
DATE STARTED 8/11/06	DATE COMPLETED 8/11/06	LOGGED BY EB	DRILLED BY EB	TYPE OF DRILL RIG #36	JOB NO. 1039
DEPTH OF HOLE 41'	DIAMETER OF HOLE 24"	CASING 92"	PERFORATIONS 41'	SAMPLING METHOD	ELEVATION 2111 62
LOCATION 162-20-603-012 Card # 30423				DRILLERS NOTES:	

DEPTH	SAMPLES	GRAPHIC	DESCRIPTION	DRILLERS NOTES
			Clay	No Time
10'			Rock	45 min
20'			Clay	5 min
30'			Rock	30 min
40'			Clay	40 min
50'				
60'				
70'				
80'				
90'				
100'				

DCNR/DWR
RECEIVED
OCT 06 2006
LAS VEGAS OFFICE