

OFFICE USE ONLY
 Log No. 101041
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29720

1. OWNER RIO Development Co, Inc. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS One Harrahs Ct. Las Vegas Nevada 89119-4312 SAVEN HEUS Lot BB
 2. LOCATION NE 1/4 SE 1/4 Sec. 01 T. 23 N. R. 61 E Clark County _____
 PERMIT NO. _____ Issued by Water Resources 191-01-612001 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>FILL- Sandy Gravel</u>	<u>0</u>	<u>0</u>	<u>1</u>	<u>1</u>
<u>CALICHE</u>	<u>1</u>	<u>1</u>	<u>3</u>	<u>2</u>
<u>SANDY GRAVEL</u>	<u>3</u>	<u>3</u>	<u>4</u>	<u>1</u>
<u>CALICHE</u>	<u>4</u>	<u>4</u>	<u>7</u>	<u>3</u>
<u>SILTY SAND</u>	<u>7</u>	<u>7</u>	<u>9</u>	<u>2</u>
<u>CLAYEY SAND</u>	<u>9</u>	<u>19 1/2</u>	<u>10 1/2</u>	<u>1 1/2</u>
<u>SANDY CLAY</u>	<u>19 1/2</u>	<u>19 1/2</u>	<u>22</u>	<u>2 1/2</u>
<u>CLAYEY SAND</u>	<u>22</u>	<u>22</u>	<u>28</u>	<u>6</u>
<u>GRAVELLY SAND</u>	<u>28</u>	<u>28</u>	<u>31</u>	<u>3</u>

8. WELL CONSTRUCTION
 Depth Drilled 31 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 3 1/2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>ASTM F480</u>	<u>sch 40</u>	<u>0</u>	<u>30</u>

 Perforations:
 Type perforation Factory slots
 Size perforation .020
 From 30 feet to 10 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 31 feet to 9 feet

9. WATER LEVEL
 Static water level NO Water feet below land surface
 Artesian flow well Dey G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality _____

Date started 9-25, 2006
 Date completed 9-25, 2006

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>N/A</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Elite Drilling Inc. Contractor
 Address 4255 W. Post Rd. Contractor
Las Vegas, Nevada
 Nevada contractor's license number issued by the State Contractor's Board 0054931
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
 Signed Thomas D. Beall
 By driller performing actual drilling on site or contractor
 Date 10-20-06