WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 10/0416
Permit No.
Basin 119

NOTICE OF INTENT NO. 25527

1. OWNER Gene Miller (Potato Potato)
MAILING ADDRESS 3856 SW 5th Street Redmond OR
ADDRESS AT WELL LOCATION Stone Cabin

2. LOCATION NW ¼ NE ¼ Sec 26 T 1 ☐/S R 46 E NYE County
PERMIT NO. 63101 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pebbles		50	95'	
12# casing 2x3x3/16				
Blue bottom				
Brackish/No odor				
Artesian water 12.1 o.c				
pace 6000 gal = 57.1 cubic				
ft water to + 50' above				
static table				
Steel plug		18x 18'		
set at		25'		
Neat cement to		25	- 1	
surface				
Casing cemented		1' below		
surface				
132 lbs pur				
25 gal H_2O				

Date started 11/14/05, 20
Date completed 11/15/05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From	To
16 Inches		1 Feet	200' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	1	—	200	

Perforations:
Type perforation Johnson well
Size perforation 30'
From 100 feet to 200' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal Per well log
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature ✓ °F Quality ✓

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address P.O. Box 358 Contractor
SES NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1876
Signed [signature] By driller performing actual drilling on site or contractor
Date 12/5/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O) 627

2005 DEC -3 AM 11:23