SW NE Sec 14 2N 46E

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Well B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Vern Fredrickson

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

I

OFFICE USE ONLY
Log No. 101047
Permit No. 66947
Basin 149

NOTICE OF INTENT NO. ~~23699~~ 25526

1. OWNER Potato Patch
MAILING ADDRESS 3856 E W Sam Speed Ct
Redmond OR 97756

ADDRESS AT WELL LOCATION Stone Cabin
25526

2. LOCATION ~~NW~~ SW ¼ ~~NE~~ SE ¼ Sec. ~~474~~ 1 TT 1 N/S R 46 E Nye County

PERMIT NO. ~~31536 66948~~ 66947 Blm 65543 31544-65021
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		1	3	
Sand Gravel		3	15	
Cobbles, Gravels		15	96	
Gravels		96	126	
Clay Sand		126	170	
Clay, Gravel		170	182	
Boulder, Clay		182	200	
Clay		200	210	
Clay Gravel		210	270	
Cobbles		270	285	
Clay Sand		285	315	
Gravels, Some				
Clay		315	340	
Boulders, Cobbles		340	542	
Some Clay layers				
N37.93753				
W116.79041 NAD27				
per FI 4-9-08				
	RC			

Date started 11/10/05, 20
Date completed 11/18/05, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1800+		8½ hrs

8. WELL CONSTRUCTION
Depth Drilled 542 Feet Depth Cased 542 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
22½ Inches	1 Feet	542 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42	250	1	542

Perforations:
Type perforation Machine Perf
Size perforation 3/16x4 Triple Rows
From 240' feet to 542 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70 feet to 542 feet

9. WATER LEVEL
Static water level C 122 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name [illegible] Drilling Inc
Contractor

Address PO 599
Contractor

SS NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 0031841 1876

Signed [signature]
By driller performing actual drilling on site or contractor

Date 12/5/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627