COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101081
Permit No.
Basin 097

NOTICE OF INTENT NO. 55537

1. OWNER Vidler/Fish Springs LLC Well #6
MAILING ADDRESS 701 West Nye Lane, Suite 201
Carson City, NV 89703

ADDRESS AT WELL LOCATION Fish Springs Ranch, North of Reno, Nevada
GPS:

2. LOCATION NE ¼ SW ¼ Sec 10 T 26 N R 19 E Washoe County

PERMIT NO. 74057/W587 (Issued by Water Resources) | N/A (APN) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt & fine sand		0	30	30
Coarse black sand		30	40	10
Black sand, fine gravel		40	45	5
Fine gravel, slicky clay		45	55	10
Fine basalt, gravel		55	80	25
Gray basalt chips		80	95	15
Mixed basalt chips		95	110	15
Multicolor gravels		110	150	40
Basalt gravel		150	205	55
Clay and rounded gravel		205	210	5
Volcanic gravel & sand		210	245	35
Sand & gravel chips		245	355	110
Volcanic gravel & clay		355	390	35
Quartz black sand		390	410	20
Clay & silt		410	430	20
Rounded quartz & sand		430	500	70
N 40 8.177 W 119 50.140 NAD83				
Hole Plug		100	105	
	N 40.136402 W 119.834651 NAD27			

Date started 05/05, 20 06
Date completed 05/17, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
700	0.4	1/2 Hour

8. WELL CONSTRUCTION

Depth Drilled 500 Feet Depth Cased 487.56 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
46 Inches	0 Feet	22 Feet
38 Inches	22 Feet	77 Feet
26 Inches	77 Feet	500 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	210.93	0.500	0	22
32	126.66	0.375	0	77
16	52.27	0.312	+2	487.56

Perforations:
Type perforation Louvered
Size perforation 0.090"
From 487.56 feet to 247 feet
From 237 feet to 117 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout ☐ 30% Grout
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 500 feet to 105 feet

9. WATER LEVEL

Static water level 90 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature 47 °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (CONTRACTOR)
Address P.O. Box 5279 (CONTRACTOR)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2308

Signed
By driller performing actual drilling on site or contractor
Date 06/06/2006

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com

COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101081
Permit No.
Basin

NOTICE OF INTENT NO. 55537

1. OWNER Vidler/Fish Springs LLC Well #6 Page 2
MAILING ADDRESS 701 West Nye Lane, Suite 201
Carson City, NV 89703

ADDRESS AT WELL LOCATION Fish Springs Ranch, North of Reno, Nevada
GPS:

2. LOCATION NE ¼ SW ¼ Sec 10 T 26 N R 19 E Washoe County

PERMIT NO. 18107/W587 (Issued by Water Resources) | N/A (APN) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness

Date started , 20
Date completed , 20

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	3.65	0.154	+2	110
3.500	7.58	0.226	+2	110

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Gravel Packed: ☐ Yes ☐ No
From feet to feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☐ Concrete Grout
☐ 30% Grout

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (CONTRACTOR)
Address (CONTRACTOR)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed
By driller performing actual drilling on site or contractor
Date

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com