WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101147
Permit No.
Basin 088

NOTICE OF INTENT NO. 55360

1. OWNER Scott & Sandra Johnson
MAILING ADDRESS 16055 Callahan Ranch Rd.
Reno, NV 89511

ADDRESS AT WELL LOCATION 16375 Callahan Ranch Rd.

2. LOCATION SW 1/4 NE 1/4 Sec. 11 T 17N N/S R 19E E Washoe County
PERMIT NO. Dom05-035 (Issued by Water Resources) 148-291-23 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil rock sand & gravel		0	20	20
Rock sand small gravel		20	60	40
Rock sand gravel some clay		60	140	80
Rock sand small gravel		140	200	60
Rock sand	x	200	220	20
Rock sand small gravels	x	220	250	30
Washoe County Well Permit # WL 050245				

Date started 12/13/2005 , 19__
Date completed 12/15/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		3

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	250	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	250

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 12/23/2005

USE ADDITIONAL SHEETS IF NECESSARY