REPORT NO. A05.077

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 101155
PERMIT NO.
BASIN 104

NOTICE OF INTENT NO. 55577

1. OWNER Ted Stokes c/o Gary Laack Construction
MAILING ADDRESS 100 Lewers Creek Rd. Carson City, NV 89704
ADDRESS OF WELL 4400 Kings Canyon Rd.
Carson City, NV 89704

2. WELL LOCATION NE 1/4 NE 1/4 SEC. 23 T 15N R 19 E Carson City COUNTY
PERMIT NO PARCEL NO 07-071-02 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS

Notes: **Perforated from 107' to surface. Pumped quik grout from TD to 25', pumped cement from 25' to surface. Cut casing off below ground level.**

Date Started 8/10/05 Date Completed 8/15/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)

8. WELL CONSTRUCTION
Depth Drilled 107 Depth Cased 107

HOLE DIAMETER (BIT SIZE)
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
10 3/4"	21.21	.188	+1	107

PERFORATIONS:
Type Perforation Size Perforation
From Feet to Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From Feet to Feet

9. WATER LEVEL
Static Water Level 28 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1132T
Signed
By driller performing actual drilling on site or contractor
Dated August 15, 2005

2006 JAN 17 PM 3:56