

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57391

1. OWNER Effie Boegle ADDRESS AT WELL LOCATION 2215 Rhodes Rd. Reno
 MAILING ADDRESS P.O. Box 18001
Reno, NV 89521
 2. LOCATION SESE 1/4 62 NE 1/4 Sec. 4 T 17N N/S R 20E E Washoe County
 PERMIT NO. 1111 Issued by Water Resources Parcel No. 017-390-14 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand		0	4	4
Gravels sand boulders		4	38	34
Sand gravel some clay		38	55	17
Brown sandy clays		55	94	39
Soft zone	x	94	99	5
Brown sandy clay		99	112	13
Brown sandy clays with some boulders		112	116	4
Rusty Brown sandy clay some gravel		116	120	4
Granite boulders weathred		120	124	4
Gravel sand clay streaks	x	124	146	22
Volcanic rock	x	146	149	3
Sandy clay		149	151	2
Volcanic boulder	x	151	156	5
Gray granite		156	160	4

Washoe County Well Permit # WL 060115
 NAD 83
 N 39.36972
 W 119.73471

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet
 From 160 Feet To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>160</u>

Perforations:
 Type perforation Machine cut
 Size perforation 3/32 x 3
 From 120 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 6/29/2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>22</u>	<u>3</u>	<u>3</u>